


1. KONDENZACIJSKI KOTAO BERETTA
 tip: Power Plus Box 1003P EXT
 Nazivni toplinski učin $Q_g=380$ kW
 $N=0,9$ kW
 $d \times \text{š} \times \text{v}$ 1700x1637x750 mm

NAZIV OBJEKTA :	CARINSKA UPRAVA PCU RIJEKA, Ul.Riva Boduli 8, 51000 RIJEKA [HRVATSKA]		
PROJECT :	BUILDING CONSTRUCTION [CROATA]		
PROJEKT :	GLAVNI PROJEKT TD-STR 25/18		
PROJECT STAGE :	PROJECT GAS HEATING INSTALLATIONS		
DIO :	INSTALACIJE PRIRODNOG PLINA		
DOC SECTION :			
INVESTITOR :	MINISTARSTVO FINACIJA, CARINSKA UPRAVA, Ul. Alexandra Von Humboldta 4, 10000 Zagreb, OIB: 18683136487		
CLIENT :			
PROJEKTANT :			
ARCHITECT OF RECORD / ARCHITECT :	 Križina 18 21000 SPLIT HRVATSKA E-MAIL: mecum@mecum.hr www.mecum.hr		
DATUM :	06 / 2018	MJERILO :	1:100
DATE :		SCALE :	
DIO :	SITUACIJA		REVIZIJA :
DOC FOLDER :	SITUATION		REVISION :
CRTEZ :	SITUACIJA - INSTALACIJE KUĆNOG PRIKLJUČKA PRIRODNOG PLINA		BROJ DJELOVA :
DRAWING :			A.1.
			BROJ CRTEŽA :
			1.1.